HIGHER TECHNICAL INSTITUTE

ELECTRICAL ENGINEERING DEPARTMENT

DIPLOMA PROJECT

DESIGN OF THE ELECTRICAL SERVICES OF A MULTISTORY BUILDING

E1402

PAVLOS

CHRISTOFOROU

JUNE 2006

HIGHER TECHNICAL INSTITUTE

ELECTRICAL ENGINEERING DEPARTMENT

DIPLOMA PROJECT

DESIGN OF THE ELECTRICAL SERVICES OF A MULTISTORY BUILDING

E1402

PAVLOS

CHRISTOFOROU

JUNE 2006



ACKNOWLEDGMENTS

8

I would like to express my sincere thanks to my project supervisor Mr. A Georgiou for his useful help and supervision in carrying out this project.

Also I would like to thank everyone who helped in any other way such as providing necessary information, specifications and technical data or suggesting methods for better presentation of the project.

Pavlos Christoforou

CONTENTS

INTRODUCTION			
1	ILLUMINATION DESIGN	5	
1.1	INTRODUCTION	5	
1.2	Methods of illumination calculations	5	
1.3	Steps of illumination calculations	6	
1.4	Illumination Calculations	7	
TA	BLE FOR ILLUMINATION DESIGN	8	
2	LIGHTING DESIGN	9	
2.1	Steps of calculations for lighting design	9	
2.2	Lighting calculation	11	
		11	
2.3	TABLE FOR LIGHTING DESIGN	13	
3	SOCKETS OUTLETS DESIGN	14	
3.1	Steps of calculations for socket outlets(ring circuit)	14	
3.2	Calculations for socket outlets(ring circuits)	17	
3.3	TABLE FOR SOCKET OUTLETS	20	
4	FIXED APPLIANCES DESIGN	21	
4.1	Steps of calculations for fixed appliances design	21	
4.2	Calculation for fixed appliances	23	
4.3	TABLE FOR COMMON FIXED APPLIANCES DESIGN	34	
5	STORAGE HEATERS DESIGN	35	
5.1	Supply	35	
5.2	Steps of calculations for storage heaters design	35	

the second s

	1	
5.3	Storage heaters calculations	37
5.4	Calculation of Main Supply Cables (ground floor)	39
5.5	Single Line Diagram	41
5.6	Calculation of Main Supply Cables for all flats	41
5.7	Single Line Diagram	43
5.8	TABLE FOR STORAGE HEATERS DESIGN	44
6	AIR CONDITION DESIGN	45
6.1	Steps of calculations for air condition design	45
6.2	Calculation for air condition design	47
6.3	TABLE FOR AIR CONDITION DESIGN	52
7	TELEPHONY INSTALLATION	53
7.1	Introduction	53
7.2	Definitions and terms	53
7.3	Telephony installation design	55
8	MAIN SUPPLY	58
8.1	Calculation of Main Supply Cable(all flats)	58
8.2	Single Line Diagram	60
8.3	Calculation of Main Supply Cable for common used	61
8.4	Single Line Diagram	62
8.5	Calculation of Main Supply Cable for lift	63
8.6	Single Line Diagram	64
8.7	TABLE FOR DISTRIBUTION BOARDS SIZE	64
9	FAULT LEVEL CALCULATIONS	65
9.1	Introduction	65
9.2	Steps of fault level calculations	65
9.3	Fault level calculations	66
10	COSTING	68

and the second second

10.1	Introduction		68
10.2	Methods of costing	٩	68
10.3	Costing		69
11	EARTHING		71
11.1	Introduction		72
11.2	Earthing principle		72
11.3	Terms		72
11.4	Earthing systems		73
12	INSPECTION AND TESTING		74
12.1	Introduction		74
12.2	Visual Inspection		74
12.3	Testing:		74

An an analysis of the second sec

INTRODUCTION

в

The project deals with the design of electrical services of a multi-storey building (block of flats).

This building consists of one floor with four flats, large parking in the basement and a ground floor with four flats.

The design of each one of the services in the building was in accordance with the appropriate regulations in the sector. After each one of the regulations was applied care was taken to obey it when selecting the appropriate materials and when calculating all the results used. Here the diversity factor taken into account was considered according to the needs of the building.

Main objectives of the project

1) To design the complete electrical installation of a multi-storey building which includes the following:

- (i) Power
- (ii) Lighting
- (iii) Telephone and TV distribution
- (iv) Lightning protection

2) To provide all necessary diagrams schedule of materials and costing including labour.

Terms and conditions

- 1. Three-phase 415Vrms 50Hz, T.T. earthing system.
- 2. Architectural drawing will be provided.
- 3. The IEE Wiring Regulations 16th Edition as currently amended and the local EAC conditions of supply must be complied.
- 4. The illumination design must be in accordance with the CIBS code.
- 5. CYTA requirements to be taken into consideration.